



防爆合格证

CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

证 号
Certificate No. CE23.6650

产品名称

Name of Product

智能压力变送器

型号及规格

Type of Product

MDM7000-1234567891011

防爆标志

Marking

Ex db II C T6 Gb

技术文件

Technical Documents

Q/MS J02.179-2022

图 号

Drawing No.

MS2.580.447、MS2.580.447WX

备 注

Note (s)

本证书备注内容详见附录

经对上述产品图样及技术文件的审查和样品的检验,其符合以下标准

By verifying the drawings and technical documents and checking samples, the product complies with the following standards

GB/T3836.1-2021

GB/T3836.2-2021

发 给:

Issued to:

麦克传感器股份有限公司

本证失效日期:

Date of Expire:

2028-04-10

发证日期:

Date of Issue:

2023-04-10

印章

Seal

主任
Director

中海油天津化工研究设计院有限公司
(国家防爆产品质量检验检测中心(天津))
(石油和化学工业电气产品防爆质量监督检验中心)
National Explosion-proof Product Quality Inspection and Testing Center(TianJin)

注: 本证仅对与批准的审查认可文件和送检样品一致的产品有效。

Note: This certificate is only valid for the documents approved and for the products that are in accord with samples tested and verified.

中心地址: 中国天津市丁字沽三号路 85 号

Center Add: No.85 No.3 Road DingZiGu Tianjin China

E-mail: pcec@pcec.com.cn

邮政编码: 300131

Post code: 300131

<http://www.pcec.com.cn>

电话/传真: 022-26651066 /26689116

Tel/ Fax: 022-26651066/26689116



防 爆 合 格 证 附 录

ANNEX OF CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

证 号 CE23.6650
Certificate No.

1. 产品型号规格: MDM7000-①②③④⑤⑥⑦⑧⑨⑩⑪。型号规格中①代表测量压力类型代码, 可为: DP、DGP、DAP、GP、AP、LP、LT; ②代表量程代码, 可为: S602D、S403D、S254D、S105D、S305D、S106D、S406S、S602G、S403G、S254G、S105G、S305G、S106G、S403A、S254A、S105A、S106A; ③代表隔离膜片材质代码, 可为: S-不锈钢 316L、H-哈氏合金 C; ④代表隔离充灌液类型, 可为: S、D; ⑤代表密封方式代码, 可为: S-氟橡胶 O 型环、P-聚四氟乙烯方形垫圈; ⑥代表信号输出方式代码, 可为: F-4mA~20mA 二线制、H-4mA~20mA+HART 二线制; ⑦代表显示方式代码, 可为: A-不带显示、C-带 LCD 显示模块; ⑧代表过程连接及泄放阀位置 (仅差压) 代码, 可为: N、H1、H2、H3; ⑨代表过程连接配件代码, 可为: A1、A2; ⑩代表固定安装配件代码, 可为: B6、B10、B8、B7 或不注; ⑪代表过程连接 (仅表压、绝压) 代码, 可为: M01、R01、R02、G01、G02 或不注。
2. 工作电压: DC10.5V/DC16.5V~55V。
3. 使用环境温度: $-40^{\circ}\text{C} \leq T_a \leq +70^{\circ}\text{C}$ 或 $-20^{\circ}\text{C} \leq T_a \leq +70^{\circ}\text{C}$ (带 LCD 显示)。
4. 关联检验报告: J2316650。

以下空白

中海油天津化工研究院设计有限公司
(国家防爆产品质量检验检测中心(天津))
(石油和化学工业电气产品防爆质量监督检验中心)
National Explosion-proof Products Quality Inspection and Testing Center(TianJin)

注: 本证仅对与批准的审查认可文件和送检样品一致的产品有效。

Note: This certificate is only valid for the documents approved and for the products that are in accord with samples tested and verified.

中心地址: 中国天津市丁字沽三号路 85 号

邮政编码: 300131

电话/传真: 022-26651066 / 26689116

Center Add: No.85 No.3 Road DingZiGu Tianjin China

Post code: 300131

Tel/ Fax: 022-26651066/26689116

E-mail: pcec@pcec.com.cn

<http://www.pcec.com.cn>